

PRESSURE TEST REQUIREMENTS

	Maximum Allowable Operating Pressure* (MAOP)		
	<i>Less than 1 PSIG to 60 PSIG</i>	<i>60 PSIG to 100 PSIG</i>	<i>Greater than 100 PSIG**</i>
Coated Steel Service 2" or Larger New, replaced, partially replaced, reinstated, or temporarily disconnected Company or customer-owned coated steel service line.	90 PSIG for one (1) hour	150 PSIG for one (1) hour	150% of MAOP for one (1) hour
Coated Steel Service Smaller than 2" New, replaced, partially replaced, reinstated, or temporarily disconnected company or customer owned coated steel service line.	90 PSIG for 10 minutes	150 PSIG for 10 minutes	150% of MAOP for 10 minutes
Bare Steel Service (Existing)	Replace with Plastic or Coated Steel	Replace with Plastic or Coated Steel	Replace with Plastic or Coated Steel
Plastic Service 2" or Larger	90 PSIG for one (1) hour	150 PSIG for one (1) hour	150% of MAOP for one (1) hour
Plastic Service Smaller than 2"	90 PSIG for 10 minutes	150 PSIG, for 10 minutes	150% of MAOP for 10 minutes

* Contact local office for specific MAOP (For new construction, see your approval letter. For replacement or repair, refer to your leak notice.)

** Additional documentation required for all lines operated at greater than 100 psig. Contact the local office for specifics.