

TERMS AND CONDITIONS

---

VI. CHARACTERISTICS OF ELECTRICITY SUPPLIED

A. The Company normally provides single phase, 60 Hertz (cycle) alternating current at approximately 120/240 Volts, or 60 Hertz three-phase, four-wire alternating current at approximately 208Y/120 Volts, and in some instances three-phase, four-wire at approximately 240/120 Volts or 480Y/277 Volts. Other voltages may also be supplied by the Company. These are listed under the nominal voltage heading of the table entitled "STANDARD SERVICE VOLTAGES AVAILABLE FROM DISTRIBUTION CLASS FACILITIES", which may be found in Section VII. B. - Voltage of the Company's filed Terms and Conditions.

B. The characteristics at which electricity will be furnished at each installation will be given in writing to the Applicant.

C. To eliminate the possibility of error or loss, the Applicant or Customer, before purchasing motors or other equipment or undertaking to install wiring, should secure from the Company in writing all necessary data relating to the characteristics of the electricity and service connections which are supplied, or will be supplied in the future.