

TERMS AND CONDITIONS

XX. PERIODIC TESTS AND CHECKS

A. Single-phase, alternating current meters will be selected for testing each year using a sampling procedure acceptable to the Commission.

B. Self-contained polyphase meters in service and polyphase or single-phase meters in service when used with instrument transformers, shall be tested in accordance with the American National Standard Code for Electricity Metering (ANSI C12).

C. Direct current meters in service shall be tested as follows:

1. Meters up to and including 8 kW rating, at least once in every 3 years.
2. Meters over 8 kW, at least once in every 1 year.